

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Fullerton, City of
303 W. Commonwealth Ave.
Fullerton CA, 92832

Project: School Lead Program
Sub Project: Lead Sampling for FSD / Maple Elementary
Project Manager: Louis Gonzalez

Work Order: 18B0760
Received: 02/07/18 17:00
Reported: 02/13/18

3010010-ABH-A 18B0760-01 (Water) Sample Date: 02/07/18 6:10 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	02/08/18	02/08/18	1806134	
-----------	----------	----	-----	----	------	----------	----------	---------	--

3010010-ABH-B 18B0760-02 (Water) Sample Date: 02/07/18 6:02 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	02/08/18	02/08/18	1806134	
-----------	----------	----	-----	----	------	----------	----------	---------	--

3010010-ABH-C 18B0760-03 (Water) Sample Date: 02/07/18 6:05 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	02/08/18	02/08/18	1806134	
-----------	----------	----	-----	----	------	----------	----------	---------	--

3010010-ABH-D 18B0760-04 (Water) Sample Date: 02/07/18 6:13 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	02/08/18	02/08/18	1806134	
-----------	----------	----	-----	----	------	----------	----------	---------	--

3010010-ABH-E 18B0760-05 (Water) Sample Date: 02/07/18 6:24 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals


Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	02/08/18	02/08/18	1806134	
-----------	----------	----	-----	----	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit

Stu Styles
Client Services Manager

Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1



Work Order: 18B0760

Report Date: 02/13/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

CITY OF FULLERTON		User ID: TFF	System: 3010010	
Maple Elementary-Partition 4 Drinkin		Station No.: 3010010-ABH-A	Sampled: 180207 06:10	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180208
Maple Elementary-Partition 4 Drinkin		Station No.: 3010010-ABH-B	Sampled: 180207 06:02	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180208
Maple Elementary-Between Partition 5		Station No.: 3010010-ABH-C	Sampled: 180207 06:05	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180208
Maple Elementary-Partition 3 Drinkin		Station No.: 3010010-ABH-D	Sampled: 180207 06:13	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180208
Maple Elementary-Partition 3 Bubbler		Station No.: 3010010-ABH-E	Sampled: 180207 06:24	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180208

Clinical Lab of San Bernardino, Inc.

Chain of Custody

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / Work Order: 18B0760

Client		City of Fullerton		Destination Laboratory		Analysis Requested		Lead SM 3113B	Total Containers	Comments	Turn Around Time (TAT)
Address:		303 West Commonwealth Ave. Fullerton, CA 92832		[X] Clinical Grand Terrace / ELAP 1088		Report Options					
Client Contact:		Jon Orndorff		[X] Hardcopy [] Client Connect							
Phone No.:		(714) 738-6746		[X] Email		FAX No.: (714) 738-3115					
System No.:		3010010		No. of Preserved Containers							
Project:		Lead Sampling for FSD		Matrix							
Sub Project:		Maple Elementary		Sample Type							
Sampled By:		Domenico D'Amico		Unpreserved							
Date:		Time:		Sample Identification							
2/7/2018		6:10		3010010-ABH-A		1 DW		1	X		7
2/7/2018		6:02		3010010-ABH-B		2 DW		1	X		7
2/7/2018		6:05		3010010-ABH-C		3 DW		1	X		7
2/7/2018		6:15		3010010-ABH-D		4 DW		1	X		7
2/7/2018		6:24		3010010-ABH-E		5 DW		1	X		7
						6 DW					7
						7 DW					
						8 DW					
						9 DW					
						10 DW					
						11 DW					
						12 DW					
						13 DW					
						14 DW					
						15 DW					
<p>Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SWR - Stormwater Runoff V - Sludge O - Other</p> <p>Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution</p> <p>TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush</p>											
Relinquished By (Sign)		Print Name / Company		Date / Time		Received By (Sign)		Print Name / Company			
<i>[Signature]</i>		ICOF		2/7/18 12:37		<i>[Signature]</i>		BRIAN BK / CLSB			
<i>[Signature]</i>		DOMENICO D'AMICO		2/7/18 17:00		<i>[Signature]</i>		K. H. H. / CLSB			
<p>(Lab Use Only)</p> <p>Condition: [] On Wet Ice [X] On Blue Ice [] Intact [] Custody Seals</p> <p>Receipt Comments: _____</p> <p>Clinical Lab Receipt Temp.: _____ °C</p>											

TEMP 6.0