


# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Fullerton, City of  
303 W. Commonwealth Ave.  
Fullerton CA, 92832

Project: School Lead Program  
Sub Project: Lead Sampling for I-SD/ Sunset Lane Elementary  
Project Manager: Louis Gonzalez

Work Order: 18C0094  
Received: 03/01/18 15:20  
Reported: 03/12/18

3010010-ACF-A 18C0094-01 (Water) Sample Date: 03/01/18 6:10 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/09/18 03/09/18 1810142

3010010-ACF-B 18C0094-02 (Water) Sample Date: 03/01/18 6:17 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/09/18 03/09/18 1810142

3010010-ACF-C 18C0094-03 (Water) Sample Date: 03/01/18 6:25 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/09/18 03/09/18 1810142

3010010-ACF-D 18C0094-04 (Water) Sample Date: 03/01/18 6:33 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/09/18 03/09/18 1810142

3010010-ACF-E 18C0094-05 (Water) Sample Date: 03/01/18 6:40 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

**Metals**


Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/09/18 03/09/18 1810142

ND Analyte NOT DETECTED at or above the reporting limit

Stu Styles  
Client Services Manager

# Clinical Laboratory of San Bernardino, Inc.

## EDT Transfer Confirmation 1



Work Order: 18C0094

Report Date: 03/12/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

CITY OF FULLERTON		User ID: TEE	System: 3010010
Sunset Lane Elementa-Partition 2 Drinkin	LEAD	Station No.: 3010010-ACF-A Result: ND Units: UG/L	Sampled: 180301 06:10 Entry No.: 01051 Analyzed: 180309
Sunset Lane Elementa-Partition 6 Drinkin	LEAD	Station No.: 3010010-ACF-B Result: ND Units: UG/L	Sampled: 180301 06:17 Entry No.: 01051 Analyzed: 180309
Sunset Lane Elementa-Partition 3 Drinkin	LEAD	Station No.: 3010010-ACF-C Result: ND Units: UG/L	Sampled: 180301 06:25 Entry No.: 01051 Analyzed: 180309
Sunset Lane Elementa-Partition 4 Drinkin	LEAD	Station No.: 3010010-ACF-D Result: ND Units: UG/L	Sampled: 180301 06:33 Entry No.: 01051 Analyzed: 180309
Sunset Lane Elementa-Partition 4 Drinkin	LEAD	Station No.: 3010010-ACF-E Result: ND Units: UG/L	Sampled: 180301 06:40 Entry No.: 01051 Analyzed: 180309

# Clinical Lab of San Bernardino, Inc.

18C0094

010/15

# Chain of Custody

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / Work Order: \_\_\_\_\_

Client		City of Fullerton		Destination Laboratory		Analysis Requested										Comments	Time (min)								
Address:		303 West Commonwealth Ave. Fullerton, CA 92832		[X] Clinical Grand Terrace / ELAP 1088																					
Client Contact: Jon Orndorff		Phone No.: (714) 738-6746 FAX No.: (714) 738-3115		[X] Hardcopy [ ] Client Connect																					
System No.: 3010010		Project: Lead Sampling for FSD		[X] Email																					
Sub Project: Sunset Lane Elementary		Sampled By: Ronnie Acosta		No. of Preserved Cont.																					
Date	Time	Sample Identification	Containers / ID	Matrix	Sample Type	Unpreserved	NH4Cl	GH806	HNO3	HCl	NaOH	Na2SO3	ZnCl2/601	Total Containers	Lead SM 3113B										
3/1/2018	6:10	3010010-ACF-A	1	DW		1								1	X										7
3/1/2018	6:17	3010010-ACF-B	2	DW		1								1	X										7
3/1/2018	6:25	3010010-ACF-C	3	DW		1								1	X										7
3/1/2018	6:53	3010010-ACF-D	4	DW		1								1	X										7
3/1/2018	6:40	3010010-ACF-E	5	DW		1								1	X										7
			6	DW																					7
			7	DW																					
			8	DW																					
			9	DW																					
			10	DW																					
			11	DW																					
			12	DW																					
			13	DW																					
			14	DW																					
			15	DW																					

Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SHR - Stormwater Runoff S - Sludge O - Other  
 Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution W-Well TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush

Relinquished By (Sign)	Print Name / Company	Date / Time	Received By (Sign)	Print Name / Company
<i>Ronnie Acosta</i>	Ronnie Acosta / COF	3/1/18 7:10am	<i>[Signature]</i>	T. N. S. B.
<i>[Signature]</i>	CCSB	4 3:20	<i>[Signature]</i>	Henry

(Lab Use Only)  
 Condition: [ ] On Wet Ice [X] On Blu Ice [ ] Intact [ ] Custody Seals Samples / COC Checked By: \_\_\_\_\_  
 Receipt Comments: \_\_\_\_\_ Clinical Lab Receipt Temp.: 7 °C