

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Fullerton, City of
303 W Commonwealth Ave.
Fullerton CA, 92832

Project: School Lead Program
Sub Project: Lead Sampling for FSD / Valencia Park Elementary
Project Manager: Louis Gonzalez

Work Order: 18C0393
Received: 03/06/18 15:23
Reported: 03/16/18

3010010-ACG-A 18C0393-01 (Water) Sample Date: 03/06/18 6:00 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/13/18 03/13/18 1811034

3010010-ACG-B 18C0393-02 (Water) Sample Date: 03/06/18 6:05 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/13/18 03/13/18 1811034

3010010-ACG-C 18C0393-03 (Water) Sample Date: 03/06/18 6:10 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B 6.5 5.0 15 ug/L 03/13/18 03/13/18 1811034

3010010-ACG-D 18C0393-04 (Water) Sample Date: 03/06/18 6:15 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/13/18 03/13/18 1811034

3010010-ACG-E 18C0393-05 (Water) Sample Date: 03/06/18 6:20 Sampler: Donald Davenport

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 03/13/18 03/13/18 1811034

ND Analyte NOT DETECTED at or above the reporting limit

Stu Styles
Client Services Manager

Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1



Work Order: 18C0393

Report Date: 03/16/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

CITY OF FULLERTON		User ID: TEE	System: 3010010				
Valencia Park Elemen-Partition 7 Drinkin	LEAD	Station No.: 3010010-ACG-A	Result: ND	Units: UG/L	Entry No.: 01051	Sampled: 180306 06:00	Analyzed: 180313
Valencia Park Elemen-Partition 7 Drinkin	LEAD	Station No.: 3010010-ACG-B	Result: ND	Units: UG/L	Entry No.: 01051	Sampled: 180306 06:05	Analyzed: 180313
Valencia Park Elemen-Partition 3 Drinkin	LEAD	Station No.: 3010010-ACG-C	Result: 6.5	Units: UG/L	Entry No.: 01051	Sampled: 180306 06:10	Analyzed: 180313
Valencia Park Elemen-Partition 3 Drinkin	LEAD	Station No.: 3010010-ACG-D	Result: ND	Units: UG/L	Entry No.: 01051	Sampled: 180306 06:15	Analyzed: 180313
Valencia Park Elemen-Partition 4 Drinkin	LEAD	Station No.: 3010010-ACG-E	Result: ND	Units: UG/L	Entry No.: 01051	Sampled: 180306 06:20	Analyzed: 180313

Clinical Lab of San Bernardino, Inc.

18C0393

Chain of Custody

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / Work Order: _____

0/0/5

Client:		City of Fullerton		Destination Laboratory		Analysis Requested												
Address:		303 West Commonwealth Ave. Fullerton, CA 92832		<input checked="" type="checkbox"/> Clinical Grand Terrace / ELAP 1088														
Client Contact: Jon Orndorff				Report Options														
Phone No.: (714) 738-6746		FAX No.: (714) 738-3115		<input checked="" type="checkbox"/> Hardcopy <input type="checkbox"/> Client Connect														
System No.: 3010010				<input checked="" type="checkbox"/> Email														
Project: Lead Sampling for FSD																		
Sub Project: Valencia Park Elementary																		
Sampled By: DONALD DAVENPORT																		
Date	Time	Sample Identification	Container(s) ID	Matrix	Sample Type	Unpreserved	NaAS203	NIACI	CaHNO6	HNO3	HCl	NaOH	Na2SO3	ZnCH601	Total Counters	Lead SM 3113B	Comments	TAT / Hold Time (TAT)
3/6/2018	6:00	3010010-ACG-A	1	DW		1									1	X		7
3/6/2018	6:05	3010010-ACG-B	2	DW		1									1	X		7
3/6/2018	6:10	3010010-ACG-C	3	DW		1									1	X		7
3/6/2018	6:15	3010010-ACG-D	4	DW		1									1	X		7
3/6/2018	6:20	3010010-ACG-E	5	DW		1									1	X		7
			6	DW														7
			7	DW														
			8	DW														
			9	DW														
			10	DW														
			11	DW														
			12	DW														
			13	DW														
			14	DW														
			15	DW														

Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SWR - Stormwater Runoff S - Sludge O - Other

Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution W-Well TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush

Relinquished By (Sign)	Print Name / Company	Date / Time	Received By (Sign)	Print Name / Company
	ICOF	3/6/18 147		CLSB
	DONALD DAVENPORT CLSB	3/6/18 323		CLSB

(Lab Use Only)
Condition: On Wet Ice On Blu Ice Intact Custody Seals Samples / COC Checked By: _____
Receipt Comments: _____ Clinical Lab Receipt Temp.: 10 °C